

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (POUSH) 2080

Sl. No.	Name of Source		Area No	Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID										
1	Iman Bahadur Gurung	2905	2-01	Max. Concent. Limits, as per NDWQS--> 25/09/2080	17.6	1	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
2	Nabaraj Dhakal	1859	2-15	25/09/2080	17.1	3	7.7	<5	NO	459	<0.1	0
3	Bhim Maya Tamang	6393	2-23	25/09/2080	17.4	1	6.6	<5	NO	244	<0.1	0
4	Bhakti Ram Gautam	390	3-04	25/09/2080	17.7	2	7.5	<5	NO	374	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	25/09/2080	17.5	2	7.6	<5	NO	534	<0.1	0
6	Jagannath Kandel	12404	4-01	24/09/2080	21.1	3	7.9	<5	NO	314	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	25/09/2080	17.7	2	7.6	<5	NO	515	<0.1	0
8	Hari Dash Sapkota	8810	6-18	24/09/2080	20.3	2	7.8	<5	NO	416	<0.1	0
9	Khem Lal Suvedi	11565	6-18	24/09/2080	20.1	3	7.6	<5	NO	419	<0.1	0
10	Java Prasad Sapkota	14255	6-19	24/09/2080	20.6	1	7.7	<5	NO	372	<0.1	0
11	Radha Devi Khanal	4705	7-10	24/09/2080	20.2	1	7.5	<5	NO	540	<0.1	0
12	Bhagawati Padhya	9305	7-12	24/09/2080	21	1	7.6	<5	NO	373	<0.1	0
13	Krishna Prasad Risal	8195	7-20	24/09/2080	20.3	1	7.8	<5	NO	283	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	24/09/2080	20.5	1	8.1	<5	NO	293	<0.1	0
15	Ramakant Sharma	623	8-A2	25/09/2080	17.9	2	6.8	<5	NO	266	<0.1	0
16	Sumitra Rana	14200	9-08	24/09/2080	20.2	3	7.6	<5	NO	408	<0.1	0
17	Churna Duttu Suvedi	11930	9-17	24/09/2080	21.1	1	7.7	<5	NO	383	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	25/09/2080	18.6	1	7.5	<5	NO	503	<0.1	0
19	Diwakar Lamichane	10770	10-02	24/09/2080	20.2	1	7.7	<5	NO	419	<0.1	0
20	Bed Maya giri	13210	10-6A	24/09/2080	20.7	1	7.3	<5	NO	679	<0.1	0
21	Gadesh Paudel	4170	10-12	25/09/2080	17.8	2	7.3	<5	NO	543	<0.1	0
22	Khim mava Baral	16688	7-16	25/09/2080	17.5	3	7.5	<5	NO	514	<0.1	0
23	Durga Maya Pradhan	6663	10-15	25/09/2080	18.4	2	7.6	<5	NO	436	0.1	0
24	Matlab Miya	3325	11-16	25/09/2080	18.1	2	7.5	<5	NO	432	<0.1	0
25	Shalik Ram Paudel	12700	12-19	25/09/2080	17.7	3	7.6	<5	NO	448	<0.1	0
26	Hemlal Dahal	15604	10-16	25/09/2080	17.7	3	7.6	<5	NO	406	<0.1	0
27	ward no 12 karyalaya	33210	12-5	25/09/2080	18	3	8.0	<5	NO	243	<0.1	0
28	Mina Kumari Paudel	13810	14-25	24/09/2080	20.3	1	8.0	<5	NO	284	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	24/09/2080	20.3	3	7.7	<5	NO	372	<0.1	0
30	Gopal Prasad Kandel	5800	8-12	24/09/2080	20.2	1	8.0	<5	NO	284	<0.1	0
31	Blank			24/09/2080								
32	Contaminated Water with Cowdung			24/09/2080								>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Chemist
Checked By: Ram Krishna Khanal

Senior administration
Checked By: Ganjaya Baral

Executive Director
Approved By: Prajapatai Dahal