

# BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

## Drinking Water Quality Test Report of Randomly Selected Customers (Jestha) 2080

S/N	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal C.C. (CFU/100)	
	Customer Name	Customer ID										Area No
1	Iman Bahadur Gurung	2905	2-01	21/02/2080	33.3	2	7.6	<5	NO	486	<0.1	0
2	Nabaraj Dhakal	1859	2-15	21/02/2080	33.1	1	6.6	<5	NO	259	<0.1	0
3	Bhim Maya Tamang	6393	2-23	21/02/2080	33.6	1	6.5	<5	NO	258	<0.1	0
4	Bhakti Ram Gautam	390	3-04	21/02/2080	33.3	1	7.4	<5	NO	671	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	21/02/2080	33.3	1	7.5	<5	NO	567	<0.1	0
6	Jagannath Kandel	12404	4-10	26/02/2080	34.7	2	7.5	<5	NO	415	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	21/02/2080	33.2	1	7.6	<5	NO	558	<0.1	0
8	Hari Dash Sapkota	8810	6-18	26/02/2080	35.3	1	7.9	<5	NO	299	<0.1	0
9	Khern Lal Suvedi	11565	6-18	26/02/2080	35.5	1	7.7	<5	NO	301	<0.1	0
10	Jaya Prasad Sapkota	14255	6-19	26/02/2080	34.6	2	7.8	<5	NO	300	<0.1	0
11	Radhna Devi Khanal	4705	7-10	26/02/2080	35.6	1	7.7	<5	NO	456	<0.1	0
12	Bhagawati Padya	9305	7-12	26/02/2080	35.4	1	7.8	<5	NO	442	<0.1	0
13	Krishna Prasad Risal	8195	7-20	26/02/2080	34.5	1	7.7	<5	NO	448	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	26/02/2080	35.3	1	7.9	<5	NO	299	<0.1	0
15	Ramakant Sharma	623	8-A2	21/02/2080	33.3	2	6.5	<5	NO	260	<0.1	0
16	Sumitra Rana	14200	9-08	26/02/2080	35.4	1	7.9	<5	NO	300	<0.1	0
17	Churna Duta Suvedi	11930	9-17	26/02/2080	35.3	1	7.6	<5	NO	405	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	21/02/2080	33.1	1	7.4	<5	NO	529	<0.1	0
19	Diwakar Lamichane	10770	10-02	26/02/2080	34.8	2	7.7	<5	NO	451	<0.1	0
20	Bed Maya giri	13210	10-6A	26/02/2080	35.1	1	7.2	<5	NO	708	<0.1	0
21	Gadesh Paudel	4170	10-12	21/02/2080	34.1	1	7.4	<5	NO	559	<0.1	0
22	Khin maya Baral	16688	7-16	21/02/2080	33.7	1	7.5	<5	NO	416	<0.1	0
23	Durga Maya Pradhan	6663	10-15	21/02/2080	33.6	1	7.7	<5	NO	493	0.1	0
24	Mattab Miya	3325	11-16	21/02/2080	33.3	1	7.5	<5	NO	486	<0.1	0
25	Shalik Ram Paudel	12700	12-19	21/02/2080	35.1	1	7.6	<5	NO	494	<0.1	0
26	Hemlal Dahal	15604	10-16	21/02/2080	34.6	2	7.0	<5	NO	461	<0.1	0
27	ward no 12 karyalaya	33210	12-5	21/02/2080	34.2	1	7.7	<5	NO	265	<0.1	0
28	Mina Kumari Paudel	13810	14-25	26/02/2080	35.1	2	7.9	<5	NO	299	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	26/02/2080	35.2	2	7.8	<5	NO	299	<0.1	0
30	Gopal Prasad Kandel	5800	8-12	26/02/2080	35.5	1	7.7	<5	NO	404	<0.1	0
31	Blank			21/02/2080								0
32	Contaminated Water with Cowdung			21/02/2080								>50

\* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Tested By: Ram Krishna Khanal

Checked By: Sanjaya Baral

Water Administration Officer

Approved By: Pragna Dira

memisr

