



BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (MAGH) 2077

S.N	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)	
	Customer Name	Customer ID										Area No
1	Iman Bahadur Gurung	2905	2-01	20/10/2077	19	<1	7.8	<5	NO	430	<0.1	0
2	Nabaraj Dhakal	1859	2-15	20/10/2077	19.6	1	7.7	<5	NO	424	<0.1	0
3	Bhim Maya Tamang	6393	2-23	20/10/2077	18.9	<1	6.6	<5	NO	228	<0.1	0
4	Bhakti Ram Gautam	390	3-04	20/10/2077	19.2	1	7.8	<5	NO	438	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	20/10/2077	19.4	1	7.7	<5	NO	585	<0.1	0
6	Jagannath Kandel	12404	4-10	22/10/2077	19.5	<2	7.9	<5	NO	486	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	20/10/2077	18.9	<1	7.7	<5	NO	587	<0.1	0
8	Hari Dash Sapkota	8810	6-18	22/10/2077	20.4	1	8.0	<5	NO	434	<0.1	0
9	Khem Lal Suvedi	11565	6-18	22/10/2077	20.5	1	7.7	<5	NO	434	<0.1	0
10	Jaya Prasad Sapkota	14255	6-19	22/10/2077	20	<2	7.4	<5	NO	682	<0.1	0
11	Radha Devi Khanal	4705	7-10	22/10/2077	20.1	1	7.4	<5	NO	571	<0.1	0
12	Bhagawati Padhya	9305	7-12	22/10/2077	19.9	1	7.9	<5	NO	430	<0.1	0
13	Krishna Prasad Risal	8195	7-20	22/10/2077	19.7	1	7.3	<5	NO	681	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	22/10/2077	19.7	1	7.4	<5	NO	593	<0.1	0
15	Ramakant Sharma	623	8-A2	20/10/2077	19.4	<1	7.2	<5	NO	386	<0.1	0
16	Sumitra Rana	14200	9-08	22/10/2077	19.8	1	7.8	<5	NO	428	<0.1	0
17	Churna Dutta Suvedi	11930	9-17	22/10/2077	20.3	<1	7.7	<5	NO	434	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	22/10/2077	18.1	<1	7.5	<5	NO	612	<0.1	0
19	Diwakar Lamichane	10770	10-02	22/10/2077	20.1	1	7.8	<5	NO	448	<0.1	0
20	Bed Maya giri	13210	10-6A	22/10/2077	19.9	<1	7.7	<5	NO	454	<0.1	0
21	Gadesh Paudel	4170	10-12	20/10/2077	19	<1	7.5	<5	NO	683	<0.1	0
22	Khim Maya Baral	16688	7-16	20/10/2077	19.4	<1	7.6	<5	NO	535	<0.1	0
23	Toya Nath Bhattarai	3153	10-30	20/10/2077	18.8	1	7.7	<5	NO	443	0.1	0
24	Mallab Miya	3325	11-23	20/10/2077	18.8	<1	7.9	<5	NO	430	<0.1	0
25	Shalik Ram Paudel	12700	12-19	20/10/2077	19.1	1	7.7	<5	NO	429	<0.1	0
26	Krishna Kumari Pantar	4680	12-16	20/10/2077	18.8	1	7.9	<5	NO	441	<0.1	0
27	Bharatpur W.N. 12 Office	12925	12-19	20/10/2077	18.7	1	7.9	<5	NO	424	<0.1	0
28	Mina Kumari Paudel	13810	14-25	22/10/2077	20.1	1	7.8	<5	NO	426	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	22/10/2077	20.3	1	7.8	<5	NO	436	<0.1	0
30	Gopal Prasad Kandel	5800	12-Aug	22/10/2077	20.3	1	8.0	<5	NO	203	<0.1	0
31	Blank			20/10/2077								0
32	Contaminated Water with Cowdung			20/10/2077								>500

* These values show lower and Upper Limits

Tested By: Ram Krishna Khanal

Chemist

Checked By: Sanjaya Baral

Signature

Executive Director

Approved By: Rajendra Dahal