

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Falgun)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μ S/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
1	Iman Bahadur Gurung	2905	2-01	2070-11-23	1	7.7	5	NO	300	0.07	0	
2	Nabaraj Dhakal	1859	2-15	2070-11-23	1	7.8	5	NO	305	0.09	0	
3	Bhim Maya Tamang	6393	2-23	2070-11-23	1	6.5	5	NO	183	0.08	0	
4	Bhakti Ram Gautam	390	3-04	2070-11-23	2	7.9	5	NO	315	0.06	0	
5	Bhagbati Paudel	13893	4-03	2070-11-23	2	7.6	5	NO	362	0.07	0	
6	Chandra Mitra Pandit	14850	4-01	2070-11-23	2	7.6	5	NO	418	0.08	0	
7	Jagannath Kandel	12404	4-10	2070-11-23	2	7.8	5	NO	421	0.07	0	
8	Sita Kumari Paudel	8480	5-09	2070-11-23	2	7.8	5	NO	424	0.08	0	
9	Hari Dash Sapkota	8810	6-18	2070-11-26	1	7.9	5	NO	301	0.06	0	
10	Khem Lal Suvedi	11565	6-18	2070-11-26	1	8.1	5	NO	280	0.07	0	
11	Jaya Prasad Sapkota	14255	6-19	2070-11-26	1	8.0	5	NO	515	0.05	0	
12	Radha Devi Khanal	4705	7-10	2070-11-26	1	7.6	5	NO	515	0.08	0	
13	Bhagawati Padhya	9305	7-12	2070-11-26	1	8.0	5	NO	273	0.08	0	
14	Krishna Prasad Risal	8195	7-20	2070-11-26	1	7.4	5	NO	497	0.05	0	
15	Yamuna Prasad Adhikari	9295	7-20	2070-11-26	3	7.6	5	NO	275	0.06	0	

* These values show lower and Upper Limits

() Values refers acceptable values only when no alternative available

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Falgun)

S.N	Name of Source			Date	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μ S/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
16	Gopal Prasad Kandel	5800	8-12	2070-11-27	1	8.1	5	NO	279	0.09	0	
17	Sumitra Rana	14200	9-08	2070-11-27	1	7.7	5	NO	350	0.07	0	
18	Churna Dutta Suvedi	11930	9-17	2070-11-27	1	7.7	5	NO	345	0.07	0	
19	Puspa Raj Sapkota	1380	10-1A	2070-11-25	1	7.7	5	NO	306	0.09	0	
20	Diwakar Lamichane	10770	10-02	2070-11-27	1	7.4	5	NO	535	0.08	0	
21	Bed Maya giri	13210	10-6A	2070-11-27	1	7.6	5	NO	363	0.07	0	
22	Gadesh Paudel	4170	10-12	2070-11-28	2	7.5	5	NO	381	0.07	0	
23	Rajendra Bahadur Bhandari	1495	10-29	2070-11-25	2	7.8	5	NO	305	0.09	0	
24	Toya Nath Bhattarai	3153	10-30	2070-11-25	1	7.8	5	NO	302	0.08	0	
25	Matlab Miya	3325	11-23	2070-11-25	1	7.7	5	NO	301	0.09	0	
26	Shalik Ram Paudel	12700	12-19	2070-11-28	1	7.9	5	NO	315	0.08	0	
27	Krishna Kumari Panta	4680	12-16	2070-11-28	1	7.9	5	NO	304	0.08	0	
28	Bharatpur W.N. 12 Office	12925	12-19	2070-11-28	1	8.3	5	NO	298	0.06	0	
29	Mina Kumari Paudel	13810	14-25	2070-11-27	2	8.1	5	NO	205	0.04	0	
30	Goma Thapa Chhetri	13165	14-25	2070-11-27	1	8.2	5	NO	280	0.05	0	

* These values show lower and Upper Limits

() Values refers acceptable values only when no alternative available