



Bharatpur Water Supply Management Board

Bharatpur, Chitwan
Drinking Water Quality Test Report of Randomly Selected Customers Falgun 2081

Name of Source			Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
Customer Name	Customer ID	Ward									
			Max. Concent. Limits, as per NDWQS-->	° C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
Narendra Gurung	37251	11	25/11/2081	23	2	7.3	<5	NO	332	<0.1	0
Jamuna Koirala	9763	11	19/11/2081	23.4	2	7.8	<5	NO	459	<0.1	0
Goushuba Gurung	29277	10	19/11/2081	23.9	1	7.8	<5	NO	492	<0.1	0
Shalik Ram Poudel	12700	12	19/11/2081	24.3	1	7.7	<5	NO	470	<0.1	3
Purna Bahadur Shrestha	5401891	2	25/11/2081	24	2	7.6	<5	NO	465	<0.1	0
Repeated Sample			28/11/2081	26.1	2	6.5			270	<0.1	0
Prakash Gurung	54011847	2	21/11/2081	21.1	2	7.7	<5	NO	503	<0.1	0
Buddhi Bahadur Bhandari	5406164	2	21/11/2081	21.1	2	7.8	<5	NO	496	<0.1	0
Satya Shai Sewa Kendra, Narayanghat	32398	3	21/11/2081	21.1	2	7.7	<5	NO	584	<0.1	0
Kopila Kandel	54056465	3	21/11/2081	22.7	2	7.7	<5	NO	560	<0.1	5
Boddha Nath Gautam	54017671	3	21/11/2081	22.7	2	7.7	<5	NO	363	<0.1	0
Repeated Sample			28/11/2081	26.1	2	7.6	<5	NO	415	<0.1	17
Nilkantha Sharma Niure	54014351	3	21/11/2081	22.4	1	7.7	<5	NO	537	<0.1	0
Repeated Sample			28/11/2081	26.1	2	7.5			567	<0.1	0
Bin Maya Gurung	5408616	4	25/11/2081	24.9	1	7.8	<5	NO	411	<0.1	0
Prem Bahadur Chokhal	54020473	4	25/11/2081	24.1	2	7.8	<5	NO	433	<0.1	0
Ramesh Kumar Karki	10281	1	21/11/2081	22.6	2	7.6	<5	NO	592	<0.1	0
Basanta Sapkota	54025745	4	25/11/2081	24.4	2	8	<5	NO	460	<0.1	0
Bishnu Kumar Kunwar	54028296	5	19/11/2081	24.1	1	8	<5	NO	204	<0.1	0
Rose Garden Public Bhawan	54019880	5	19/11/2081	23.8	1	7.7	<5	NO	322	<0.1	0
Hima Adhikari	54039097	5	19/11/2081	23.9	1	8	<5	NO	204	<0.1	0
Saroj Ghimire	54041248	5	19/11/2081	23.7	3	8	<5	NO	302	<0.1	0
Indra Maya Gurung	37700	11	23/11/2081	24.1	3	8	<5	NO	222	<0.1	0
Sushree Mamata Sharma	54028888	6	23/11/2081	23.7	1	8	<5	NO	303	<0.1	0
Pashupati Adhikari	54037915	6	21/11/2081	23.2	2	8.1	<5	NO	275	<0.1	0
Shree Prasad Adhikari	9606	7	23/11/2081	24.1	2	7.9	<5	NO	416	<0.1	0
Durga Bahadur Thapa Samet	54015405	7	23/11/2081	24.1	2	8	<5	NO	303	<0.1	0
Tribikram Thapa Chhetri	54015070	7	23/11/2081	23.3	1	8	<5	NO	302	<0.1	0
Chigana Village	54017018	7	23/11/2081	24.1	1	7.9	<5	NO	426	<0.1	0
Sanadial Shrestha	54025862	8	23/11/2081	24.5	1	7.8	<5	NO	424	<0.1	0

Approved By: Sanjay Baral
Executive Director

Tested By : Ram Krishna Khanal

1	Harishchandra Ghimire	54011604	8	10	23/11/2081	24.6	2	8	<5	NO	305	<0.1	0
2	Sangita Poudel	54023006	8	16	23/11/2081	25.2	12	7.8	<5	NO	410	<0.1	0
3	Mahaendra Lal Shrestha	5409075	8	14	23/11/2081	24.2	1	7.8	<5	NO	408	<0.1	0
4	Buddhi Prasad Sapkota	5405571	9	13	23/11/2081	25.3	1	7.8	<5	NO	409	<0.1	0
5	Chandradevi Sapkota	54028400	9	19	23/11/2081	24.6	2	7.9	<5	NO	411	<0.1	0
6	Hema Lama Balampaki	54041442	9	21	23/11/2081	24.7	1	7.8	<5	NO	415	<0.1	0
7	Chandra Kumari Jarga	54033810	9	29	23/11/2081	24.3	1	7.8	<5	NO	407	<0.1	0
8	Uddhav Bista	5401428	10	21B	19/11/2081	23.1	1	7.6	<5	NO	520	<0.1	0
9	Netra Kala Regmi	54016782	10	6	19/11/2081	23.4	2	7.8	<5	NO	521	<0.1	12
10	Nepal Electricity Authority	54013247	10	26B	21/11/2081	22.8	2	7	<5	NO	286	<0.1	0
11	Repeated Sample				28/11/2081	26	3	7.5	<5	NO	549	<0.1	0
12	Rohini Raj Paudel	12294	12	18	25/11/2081	24.2	2	7.7	<5	NO	409	<0.1	0
13	Ramakanta Sharma	623	2	8A	25/11/2081	24.5	1	7	<5	NO	354	<0.1	0
14	Bha.Ma.Na.Pa.11 Ward	54023213	11	12	19/11/2081	23.5	1	7.4	<5	NO	362	<0.1	0
15	Sunitra Rokka	54036707	11	18A	19/11/2081	23.8	1	8	<5	NO	252	<0.1	0
16	Radha Krishna Shrestha	7925	2	1A	21/11/2081	21.2	2	7.8	<5	NO	524	<0.1	0
17	Bimala Devi Neupane	54018238	12	4	19/11/2081	23.7	1	7.9	<5	NO	266	<0.1	0
18	Anudi Foods Pvt. Ltd.	54022667	12	4	19/11/2081	23.8	2	8.1	<5	NO	251	<0.1	0
19	Bhumi sara Bhurtel	54010993	10	3A	21/11/2081	22.7	2	7.7	<5	NO	540	<0.1	0
20	Narayan Prasad Adhikari	54034542	12	23	19/11/2081	23.8	3	7.8	<5	NO	368	<0.1	0
21	Jayram Giri	54041314	13	1	21/11/2081	23.4	2	8.1	<5	NO	275	<0.1	0
22	Bir Bahadur Magar	54041226	13	1	21/11/2081	23.7	2	8.1	<5	NO	237	<0.1	0
23	Bhawana Pokhrel	54040583	13	1	21/11/2081	23.3	2	8	<5	NO	275	<0.1	0
24	Buddhiram Mahato	54040052	14	1	21/11/2081	23.6	1	8.1	<5	NO	237	<0.1	0
25	Netra Prasad Adhikari	54025582	14	1	21/11/2081	23.3	2	8.1	<5	NO	236	<0.1	0
26	Shambhu Mahato	54039115	14	1	21/11/2081	23.6	1	8.1	<5	NO	236	<0.1	0
27	Dhurba Raj Poudel	54036968	15	1N	19/11/2081	23.8	1	7.8	<5	NO	225	<0.1	0
28	Binod Prasad Sharma	54032942	15	1	19/11/2081	23.7	1	7.9	<5	NO	307	<0.1	0
29	Sabitri Kandel	54031959	15	10	19/11/2081	24.3	2	8.1	<5	NO	312	<0.1	>20
30	Repeated Sample				28/11/2081								0
31	Bharatpur Mahanagarपालिका-16	54026293	16	1	19/11/2081	23.9	2	7.9	<5	NO	321	<0.1	0
32	Chandra Prakash Paudel	54039375	16	1	19/11/2081	24.1	1	7.9	<5	NO	324	<0.1	0
33	Nar Bahadur Gurung	54038247	16	0	19/11/2081	23.7	1	7.8	<5	NO	315	<0.1	0
34	Ramial Mahato	54022975	22	1	21/11/2081	23.3	2	8.1	<5	NO	236	<0.1	0
35	Balram Poudel	54022968	22	1	21/11/2081	23.4	2	8.1	<5	NO	236	<0.1	>50
36	Contaminated Water with Cowdung				19/11/2081								

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Chemist

Tested By : Ram Krishna Khanal

Approved By: Sanjay Baral
Executive Director