

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers Chaitra 2081

Customer Name	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer ID	Ward Zone									
			Max. Concent. Limits, as per NDWQS->	° C							
Ramesh Kumar Karki	10281	1 18	29/12/2081	27.4	2	7.6	<5	N O	635	<0.1	0
Purna Bahadur Shrestha	5401891	2 6B	29/12/2081	27.3	2	7.6	<5	N O	451	<0.1	0
Prakash Gurung	54011847	2 4	29/12/2081	27.8	2	7.5	<5	N O	620	<0.1	0
Buddhi Bahadur Bhandari	5406164	2 11	29/12/2081	27.1	2	7.6	<5	N O	562	<0.1	0
Ramakanta Sharma	623	2 8A	29/12/2081	26.9	1	6.9	<5	N O	340	<0.1	0
Radha Krishna Shrestha	7925	2 1A	29/12/2081	27.2	1	7.7	<5	N O	521	<0.1	0
Satya Shai Sewa Kendra, Narayanghat	32398	3 9	29/12/2081	27.3	1	7.5	<5	N O	637	<0.1	0
Kopila Kandel	54036465	3 4	29/12/2081	27.6	1	7.5	<5	N O	567	<0.1	0
Boddha Nath Gautam	54017671	3 12	29/12/2081	27.9	1	7.5	<5	N O	593	<0.1	0
Nilkantha Sharma Niure	54014351	3 10	29/12/2081	27.6	1	7.6	<5	N O	595	<0.1	0
Bin Maya Gurung	5408616	4 15	26/12/2081	30.0	1	7.8	<5	N O	417	<0.1	0
Prem Bahadur Chokhal	54020473	4 6	26/12/2081	24.1	2	7.7	<5	N O	448	<0.1	0
Basanta Sapkota	54025745	4 16N	26/12/2081	30.3	1	7.9	<5	N O	419	<0.1	0
Ward No 4 Wada Karyalya	54012999	4 20	26/12/2081	29.4	1	7.7	<5	N O	414	<0.1	0
Bishnu Kumar Kunwar	54028296	5 5	20/12/2081	26.8	2	8.0	<5	N O	209	<0.1	0
Rose Garden Public Bhawan	54019880	5 19	20/12/2081	26.8	2	7.7	<5	N O	326	<0.1	0
Hima Adhikari	54039097	5 5	20/12/2081	26.8	2	8.0	<5	N O	208	<0.1	0
Saroj Ghimire	54041248	5 25	20/12/2081	26.6	2	8.0	<5	N O	307	<0.1	0
War No 6 Ward Office	54037750	6 15	22/12/2081	26.9	2	8.0	<5	N O	224	<0.1	0
Sushree Mamata Sharma	54028888	6 1	26/12/2081	29.2	1	8.0	<5	N O	311	<0.1	0
Pashupati Adhikari	54037915	6 0	22/12/2081	27.1	2	8.1	<5	N O	280	<0.1	0
Jhabsiwor Dhakal	5409606	7 16	26/12/2081	29.6	2	7.8	<5	N O	421	<0.1	0
Durga Bahadur Thapa Samet	54015405	7 3	26/12/2081	29.7	1	7.7	<5	N O	428	<0.1	0
Tribikram Thapa Chhetri	54015070	7 14.1	26/12/2081	29.7	2	7.8	<5	N O	417	<0.1	0
Chetana Village	54017018	7 16	26/12/2081	29.8	1	7.9	<5	N O	443	<0.1	0
Sanadial Shrestha	54025862	8 8	26/12/2081	29.6	1	7.7	<5	N O	439	<0.1	0
Harishchandra Ghimire	54011604	8 10	26/12/2081	29.4	2	7.8	<5	N O	423	<0.1	0
Sangita Poudel	54023006	8 16	26/12/2081	29.5	1	7.9	<5	N O	311	<0.1	0
Mahaendra Lal Shrestha	5409075	8 14	26/12/2081	29.7	1	7.8	<5	N O	401	<0.1	0
Buddhi Prasad Sapkota	5405571	9 13	26/12/2081	29.7	2	7.7	<5	N O	417	<0.1	0
Chandradevi Sapkota	54028400	9 19	26/12/2081	29.4	2	7.8	<5	N O	419	<0.1	0
Hema Lama Balanpaki	54041442	9 21	26/12/2081	29.2	1	7.7	<5	N O	417	<0.1	0

Chemist

Executive Director

Chandra Kumari Jarga	54033810	9	29	26/12/2081	29.1	2	7.7	<5	N O	456	<0.1	0
Goushuba Gurung	29277	10	18 B	20/12/2081	26.1	2	7.6	<5	N O	554	<0.1	0
Uddhav Bista	540142830	10	21B	29/12/2081	28.0	1	7.7	<5	N O	444	<0.1	0
Netra Kala Regmi	54016782	10	6	29/12/2081	27.9	1	7.8	<5	N O	482	<0.1	0
Nepal Electricity Authority	54013247	10	26B	20/12/2081	26.5	2	7.6	<5	N O	559	<0.1	0
Bhumi Sara Bhurtel	10993	10	3A	29/12/2081	27.3	1	7.6	<5	N O	549	<0.1	0
Jamuna Koirala	9763	11	8	20/12/2081	25.9	1	7.7	<5	N O	461	<0.1	0
Bha.Ma.Na.Pa.11 Ward	54033213	11	12	29/12/2081	27.1	1	7.5	<5	N O	362	<0.1	0
Sumitra Rokka	54036707	11	18A	20/12/2081	26.2	2	8.0	<5	N O	251	<0.1	0
Kamala Devi	54010281	12	24	29/12/2081	27.3	1	7.5	<5	N O	347	<0.1	0
Shalik Ram Poudel	12700	12	21	20/12/2081	27.0	2	7.6	<5	N O	493	<0.1	0
Bimala Devi Neupane	54018238	12	4	20/12/2081	26.5	1	8.0	<5	N O	253	<0.1	0
Amudi Foods Pvt. Ltd.	54022667	12	4	20/12/2081	26.7	1	8.0	<5	N O	253	<0.1	0
Narayan Prasad Adhikari	54034542	12	23	20/12/2081	25.9	2	7.7	<5	N O	442	<0.1	0
Jayram Giri	54041314	13	1	22/12/2081	26.9	2	8.1	<5	N O	280	<0.1	0
Bir Bahadur Magar	54041226	13	1	22/12/2081	27.7	3	8.0	<5	N O	280	<0.1	0
Bhawana Pokhrel	54040583	13	1	22/12/2081	27.3	2	8.0	<5	N O	280	<0.1	0
Buddhiram Mahato	54040052	14	1	22/12/2081	27.4	2	8.0	<5	N O	281	<0.1	0
Netra Prasad Adhikari	54025582	14	1	22/12/2081	27.5	2	8.0	<5	N O	244	<0.1	0
Shambhu Mahato	54039115	14	1	22/12/2081	27.2	3	8.0	<5	N O	280	<0.1	0
Dhurba Raj Poudel	54036968	15	1N	20/12/2081	26.7	2	8.0	<5	N O	223	<0.1	0
Binod Prasad Sharma	54032942	15	1	20/12/2081	26.4	3	7.9	<5	N O	310	<0.1	0
Sabitri Kandel	54031959	15	10	20/12/2081	26.3	2	7.9	<5	N O	310	<0.1	0
Bharatpur Mahanagarपालिका-16	54026293	16	1	20/12/2081	26.3	2	7.8	<5	N O	315	<0.1	0
Chandra Prakash Paudel	54039375	16	1	20/12/2081	26.5	1	7.8	<5	N O	325	<0.1	0
Nar Bahadur Gurung	54038247	16	0	20/12/2081	26.2	2	7.8	<5	N O	326	<0.1	0
Ramlal Mahato	54022975	22	1	22/12/2081	27.2	2	8.0	<5	N O	245	<0.1	0
Balram Poudel	54022968	22	1	22/12/2081	26.7	3	8.1	<5	N O	247	<0.1	0
Contaminated Water with Cowdung				20/12/2081								>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Checked By
Ram Krishna Khanal

Chemist

Verified By
Sanjay Baral

Executive Director