


BHARATPUR WATER SUPPLY MANAGEMENT BOARD
 Drinking Water Quality Test Report of Randomly Selected Customers (POUSH) 2077



S.N	Name of Source			Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Area No									
1	Iman Bahadur Gurung	2905	2-01	9/20/2077	18.1	<1	7.9	<5	NO	1500	<0.1	0
2	Nabaraaj Dhakal	1859	2-15	9/20/2077	17.8	1	7.5	<5	NO	522	<0.1	0
3	Bhim Maya Tamang	6393	2-23	9/20/2077	18	<1	7.8	<5	NO	434	<0.1	0
4	Bhakti Ram Gautam	390	3-04	9/20/2077	17.9	1	8.0	<5	NO	248	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	9/20/2077	18	<2	7.9	<5	NO	246	<0.1	0
6	Jagannath Kandel	12404	4-10	9/28/2077	17.6	<1	8.0	<5	NO	251	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	9/20/2077	18.4	<1	7.4	<5	NO	629	<0.1	0
8	Hari Dash Sapkota	8810	6-18	9/28/2077	17.6	1	7.4	<5	NO	596	<0.1	0
9	Khem Lal Suedi	11565	6-18	9/28/2077	17.9	<2	7.1	<5	NO	341	<0.1	0
10	Jaya Prasad Sapkota	14255	6-19	9/28/2077	17.9	1	7.6	<5	NO	505	<0.1	0
11	Radha Devi Khanal	4705	7-10	9/28/2077	17.9	1	7.6	<5	NO	412	<0.1	0
12	Bhagawati Padhya	9305	7-12	9/28/2077	17.9	1	7.6	<5	NO	428	<0.1	0
13	Krishna Prasad Risal	8195	7-20	9/28/2077	17.8	1	7.7	<5	NO	452	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	9/28/2077	17.8	<1	7.8	<5	NO	429	<0.1	0
15	Ramakant Sharma	623	8-A2	9/20/2077	17.8	<1	7.8	<5	NO	406	<0.1	0
16	Sumitra Rana	14200	9-08	9/28/2077	17.9	1	7.8	<5	NO	397	<0.1	0
17	Churna Dutta Suedi	11930	9-17	9/28/2077	17.8	<1	7.8	<5	NO	250	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	9/20/2077	18.4	<1	8.1	<5	NO	412	<0.1	0
19	Diwakar Lamichane	10770	10-02	9/28/2077	17.7	1	7.4	<5	NO	398	<0.1	0
20	Bed Maya giri	13210	10-6A	9/28/2077	17.6	<1	7.9	<5	NO	249	<0.1	0
21	Gadesh Paudel	4170	10-12	9/20/2077	18	<1	8.0	<5	NO	248	<0.1	0
22	Rajendra Bdr. Bhandari	1495	10-29	9/20/2077	18	<1	8.1	<5	NO	398	<0.1	0
23	Toya Nath Bhattarai	3153	10-30	9/20/2077	18.2	1	7.9	<5	NO	393	<0.1	0
24	Matlab Miya	3325	11-23	9/20/2077	18	<1	7.9	<5	NO	249	<0.1	0
25	Shalik Ram Paudel	12700	12-19	9/20/2077	18.3	1	8.1	<5	NO	253	<0.1	0
26	Krishna Kumari Pantla	4680	12-16	9/20/2077	18.4	1	8.1	<5	NO	248	<0.1	0
27	Bharatpur W.N. 12 Office	12925	12-19	9/20/2077	18	1	8.1	<5	NO	416	<0.1	0
28	Milna Kumari Paudel	13810	14-25	9/28/2077	17.7	1	7.9	<5	NO	398	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	9/28/2077	17.8	1	8.0	<5	NO	394	<0.1	0
30	Gopal Prasad Kandel	5800	12-Aug	9/28/2077	17.6	1	8.0	<5	NO	394	<0.1	0
31	Blank			9/20/2077								
32	Contaminated Water with Cowdung			9/20/2077								>50

* These values show lower and Upper Limits

Tested By: Ram Krishna Khanal
 Chemist

Checked By: Sanjaya Parajapati
 Asst. Municipal Engineer

Approved By: Pradyuman Dahal
 Executive Engineer