

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (MARG) 2077

S. N	Name of Source		Date ↓	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
		Area No	Max. Concent. Limits, as per NDWQS →								
1	Iman Bahadur Gurung	2905	22/8/2077	21.2	<1	7.4	<5	NO	414	<0.1	0
2	Nabataj Dhakal	1859	22/8/2077	21.6	1	7.1	<5	NO	225	<0.1	0
3	Bhim Maya Tamang	6393	22/8/2077	21.6	<1	7.7	<5	NO	233	<0.1	0
4	Bhakti Ram Gautam	390	22/8/2077	21.2	<1	7.4	<5	NO	405	<0.1	0
5	Chandra Mitra Pandit	14850	22/8/2077	21.5	1	7.3	<5	NO	249	<0.1	0
6	Jagannath Kandel	12404	24/8/2077	20	2	8.1	<5	NO	402	<0.1	0
7	Narayan Pd. Shrestha	7740	22/8/2077	21.6	1	7.5	<5	NO	424	<0.1	0
8	Hari Dash Sapkota	8810	24/8/2077	20.1	1	7.9	<5	NO	416	<0.1	0
9	Khem Lal Suvedi	11565	24/8/2077	20.1	<2	8.0	<5	NO	551	<0.1	0
10	Jaya Prasad Sapkota	14255	24/8/2077	20.3	<2	7.9	<5	NO	527	<0.1	0
11	Radha Devi Khanal	4705	24/8/2077	20.6	<1	7.6	<5	NO	394	<0.1	0
12	Bhagawati Padhya	9305	24/8/2077	20.9	1	7.6	<5	NO	415	<0.1	0
13	Krishna Prasad Risal	8195	24/8/2077	20.2	1	7.6	<5	NO	350	<0.1	0
14	Yamuna Pd. Adhikari	9295	24/8/2077	19.8	1	7.7	<5	NO	454	<0.1	0
15	Ramakant Sharma	623	22/8/2077	21.7	<1	7.1	<5	NO	22	<0.1	0
16	Sumitra Rana	14200	24/8/2077	20.4	<2	7.5	<5	NO	392	<0.1	0
17	Churna Dutta Suvedi	11930	24/8/2077	10.7	<2	7.9	<5	NO	607	<0.1	0
18	Puspa Raj Sapkota	1380	22/8/2077	21.6	<1	7.9	<5	NO	407	<0.1	0
19	Diwakar Lamichane	10770	24/8/2077	20.6	<2	7.4	<5	NO	396	<0.1	0
20	Bed Maya qiri	13210	24/8/2077	20.6	<2	7.5	<5	NO	397	<0.1	0
21	Gadesh Paudel	4170	22/8/2077	21.6	<1	7.4	<5	NO	327	<0.1	0
22	Rajendra Bdr. Bhandari	1495	22/8/2077	21.4	<1	7.8	<5	NO	249	<0.1	0
23	Tova Nath Bhattarai	3153	22/8/2077	21.7	1	7.8	<5	NO	399	<0.1	0
24	Matlab Miya	3325	22/8/2077	21.3	<1	7.9	<5	NO	248	<0.1	0
25	Shalik Ram Paudel	12700	22/8/2077	21.6	1	7.3	<5	NO	407	<0.1	0
26	Krishna Kumari Panta	4680	22/8/2077	21.6	<1	7.8	<5	NO	406	<0.1	0
27	Bharatpur W.N. 12 Office	12925	22/8/2077	21.4	1	7.6	<5	NO	432	<0.1	0
28	Mina Kumari Paudel	13810	24/8/2077	20.1	2	8.0	<5	NO	638	<0.1	0
29	Goma Thapa Chhetri	13165	24/8/2077	20.5	<2	7.9	<5	NO	402	<0.1	0
30	Gopal Prasad Kandel	5800	24/8/2077	20.2	1	7.9	<5	NO	400	<0.1	0
31	Blank		22/8/2077								>50
32	Contaminated Water		22/8/2077								

* These values show lower and Upper Limits



Chemist

Officer

Executive Director