


**BHARATPUR WATER SUPPLY MANAGEMENT BOARD**

Bharatpur, Chitwan

**Drinking Water Quality Test Report of Randomly Selected Customers (KARTIK) 2077**

S. N	Name of Source		Customer ID	Area No	Date ↓ Max. Concent. Limits, as per NDWQS →	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)
	Customer Name												
1	Iman Bahadur Gurung	2905	2-01	18/7/2077	26.9	<1	7.4	<5	NO objectionable	1500	0.1-0.2	0	
	Repeated sample			23/7/2077						395	<0.1	4	
2	Nabataj Dhakal	1859	2-15	18/7/2077	26.7	1	7.1	<5	NO	353	<0.1	0	
3	Bhim Mava Tamang	6393	2-23	18/7/2077	27.4	<1	7.7	<5	NO	405	<0.1	0	
4	Bhakti Ram Gautam	390	3-04	18/7/2077	27.3	<1	7.4	<5	NO	383	<0.1	0	
5	Chandra Mitra Pandit	14850	4-01	18/7/2077	26.6	1	7.3	<5	NO	374	<0.1	0	
6	Jagannath Kandel	12404	4-10	23/7/2077	25.2	2	8.1	<5	NO	440	<0.1	0	
7	Narayan Pd. Shrestha	7740	4-01A	18/7/2077	27	1	7.5	<5	NO	399	<0.1	0	
8	Hari Dash Sapkota	8810	6-18	23/7/2077	25.2	1	7.9	<5	NO	420	<0.1	0	
9	Khem Lal Suvedi	11565	6-18	23/7/2077	25.6	<2	8.0	<5	NO	358	<0.1	0	
10	Jaya Prasad Sapkota	14255	6-19	23/7/2077	25.4	<2	7.9	<5	NO	374	<0.1	0	
11	Radha Devi Khanal	4705	7-10	23/7/2077	25.1	<1	7.6	<5	NO	642	<0.1	0	
12	Bhagawati Padya	9305	7-12	23/7/2077	25	1	7.6	<5	NO	599	<0.1	0	
13	Krishna Prasad Risal	8195	7-20	23/7/2077	24.9	1	7.6	<5	NO	636	<0.1	0	
14	Yamuna Pd. Adhikari	9295	7-20	23/7/2077	25	1	7.7	<5	NO	573	<0.1	0	
15	Ramakant Sharma	623	8-A2	18/7/2077	26.8	<1	7.1	<5	NO	345	<0.1	0	
16	Sumitra Rana	14200	9-08	23/7/2077	25.3	<2	7.5	<5	NO	542	<0.1	0	
17	Churna Dutta Suvedi	11930	9-17	23/7/2077	25.1	<2	7.9	<5	NO	373	<0.1	0	
18	Puspa Raj Sapkota	1380	10-1A	18/7/2077	27.7	<1	7.9	<5	NO	410	<0.1	0	
19	Diwakar Lamichane	10770	10-02	23/7/2077	25.3	<2	7.4	<5	NO	631	<0.1	0	
20	Bed Mava giri	13210	10-6A	23/7/2077	25.7	<2	7.5	<5	NO	643	<0.1	0	
21	Gadesh Paudel	4170	10-12	18/7/2077	27.6	<1	7.4	<5	NO	390	<0.1	0	
22	Ralendra Bdr. Bhandari	1495	10-29	18/7/2077	27.4	<1	7.8	<5	NO	404	<0.1	0	
23	Tova Nath Bhattarai	3153	10-30	18/7/2077	27.3	1	7.8	<5	NO	406	<0.1	10	
	Repeated sample			23/7/2077								0	
24	Matlab Miya	3325	11-23	18/7/2077	26.7	<1	7.9	<5	NO	389	<0.1	0	
25	Shalik Ram Paudel	12700	12-19	18/7/2077	27.4	1	7.3	<5	NO	384	<0.1	0	
26	Krishna Kumari Panta	4680	12-16	18/7/2077	27.1	<1	7.8	<5	NO	405	<0.1	0	
27	Bharatpur W.N. 12 Office	12925	12-19	18/7/2077	27.2	1	7.6	<5	NO	404	<0.1	7	
	Repeated sample			23/7/2077								0	
28	Mina Kumari Paudel	13810	14-25	23/7/2077	25.3	2	8.0	<5	NO	371	<0.1	0	
29	Goma Thapa Chhetri	13165	14-25	23/7/2077	25.2	<2	7.9	<5	NO	362	<0.1	0	
30	Gopal Prasad Kandel	5800	12-8	23/7/2077	25.6	1	7.9	<5	NO	375	<0.1	0	
31	Blank			18/7/2077								0	
32	Contaminated Water			18/7/2077								>50	

\* These values show lower and Upper Limits



Chemist

Sub-Inspector Officer

Executive Director